



# Test Report

Project designation	<b>Type Test according to IEC/EN 60947-3 in conjunction with IEC/EN 60947-1</b>		
Product description	<b>Low-Voltage Fuse-Switch-Disconnectors for Cylindrical Fuse-Links 8x31 type EFD 8</b>		
Client	ETI Elektroelement d.d. Obrezija 5 1411 Izlake SLOVENIA		
Order from / No.	01/2014 / ---		
Project number	2.03.02769.1.0/EFD8		
Date of issue	17.04.2014	Test engineer	Ing.J.Ainetter
Total number of issues / No.	1 / 1		
Number of pages	5		
Annex: Number of pages	CB - Test Report No. 2.03.02769.1.0/EFD8/CB (70 pages) CCA - Test Report No. 2.03.02769.1.0/EFD8/CCA (2 pages)		

The results relate exclusively to the items tested.

This report may only be reproduced or published in full, without omissions, alterations or additions.

The reproduction or publishing of extracts from this report require the written approval of the testing laboratory.

## Test item

### Identification:

Low-voltage fuse-switch-disconnectors for cylindrical fuse-links 8x31 type EFD 8

Manufacturer:	ETI Elektroelement d.d.
Trademark:	ETI
Number of poles:	1p, 1p+N, 2p, 3p, 3p+N
Rated operational voltage:	400V a.c.
Rated operational current:	Up to 20A (with gG fuse-links) Up to 10A (with aM fuse-links)
Rated frequency:	50/60Hz

### Technical data, Description:

See page 4

## Testing location, Period of testing

### Testing location:

AIT Austrian Institute of Technology GmbH  
Business Unit Electric Energy Systems  
Power Service Center  
Giefinggasse 2  
1210 Vienna  
AUSTRIA

### Period of testing:

10/2008 to 12/2008 and 02/2014 to 03/2014

## Test(s)

### Test(s) performed:

Type test

### Test standard(s):

IEC 60947-1:2011 (Edition 5.1) and EN 60947-1:2007+A1:2011  
IEC 60947-3:2012 (Edition 3.1) and EN 60947-3:2009+A1:2012

### Test procedure(s):

CB Scheme and CCA Scheme

## Result

The low-voltage fuse-switch-disconnectors for cylindrical fuse-links 8x31 type EFD 8 have passed the type test successfully.



Seal

Test engineer

A handwritten signature in black ink, appearing to read "J. Ainetter".


Ing. Johann Ainetter

Responsible for the content

A handwritten signature in black ink, appearing to read "K. Farthofer".

Ing. Karl Farthofer

## Testing laboratory



**ACCREDITED**  
 according to  
**EN ISO/IEC 17025**  
 confirmed by  
**BMWFI**  
 with GZ 92714/237-IV/9/00



**CERTIFIED**  
 according to  
**ISO 9001**  
 confirmed by  
**Quality Austria**  
 with Reg. No. 00229/1



**RECOGNIZED CB TESTING LABORATORY**  
 confirmed by  
**International Electrotechnical Commission**  
 under the responsibility of  
**OVE**  
 as the National Certification Body

## Technical data, Description

Test item	Low-voltage fuse-switch-disconnectors for cylindrical fuse-links 8x31
Trademark	ETI
Model/Type reference	EFD 8
Manufacturer	ETI Elektroelement d.d.
Factory location	1411 Izlake, Obrezija 5, SLOVENIA
Type of terminals	Pillar terminals
Method of operation	Dependent manual operation
Switching positions	O / I
Number of poles	1p, 1p+N, 2p, 3p, 3p+N
Nature of supply	AC
Utilization category	AC-22B at 400V/20A
Rated operational voltage	400V
Rated operational current	20A (with gG fuse-links) 10A (with aM fuse-links)
Rated frequency	50/60Hz
Conventional free air thermal current	20A max. (with gG fuse-links) 10A max. (with aM fuse-links)
Rated insulation voltage	690V
Rated impulse withstand voltage	8kV
Rated short-time withstand current	240A / 1s
Rated conditional short-circuit current	100kA (with 20A gG fuse-links) 50kA (with 10A aM fuse-links)
Kind of protective device	Cylindrical fuse-links 8x31, up to 20A (gG) Cylindrical fuse-links 8x31, up to 10A (aM)
Max. power dissipation of protective device	gG fuse-links: 2,3W aM fuse-links: 0,6W
Degree of protection	IP20

## Measuring equipment

Measured quantity	Device	Manufacturer	Code
Voltage (tests up to 10kA)	Voltage divider 1:2000 Difference amplifier AM 502 Signal memory recorder TRA 800	AIT Tektronix W&W	- AM 502/1...3 TRA800
Current (tests up to 10kA)	Lin. Current transformer LGSSO Burden 1Ω Signal memory recorder TRA 800	Ritz AIT W&W	WLIN5000/1...3 - TRA800
Voltage (tests above 10kA)	Insulating measuring amplifier Arcus Signal memory recorder 2580-P	Rohrer Nicolet	T908D 2580-P
Current (tests above 10kA)	Lin current transformer LGSSO Burden 0,7mΩ Signal memory recorder 2580-P	Ritz AIT Nicolet	WLIN6000.HVF/1...3 - 2580-P
Current (tests at reduced voltage)	Current transformer GE 4461 Current transformer AET110 True-RMS amperemeter Cl. 0,5 Digital multimeter Fluke 185	Goerz Siemens Norma Fluke	WI600/1...3 WI4000/1...3 A0,5/4 FLUKE185/2
Transient recovery voltage	Adjustment equipment for TRV Oscilloscope G 801.1	AIT Tektronix	- G801.1
Dielectric properties	High-voltage test equipment 90-1F with measuring equipment Impulse tester 35 Impulse voltmeter 64M Oscilloscope 9430	Elabo Haefely Haefely Le Croy	HSG5KV G304 G502 G805
Leakage current	High-voltage test equipment 90-1F Digital multimeter Fluke 185 Digital multimeter Fluke 187	Elabo Fluke Fluke	HSG5KV FLUKE185/2 G922
Time	Signal memory recorders Digital stopwatch	W&W, Nicolet Quantum	TRA800, 2580-P 938-3
Temperature	Data Logger Unit 34970A Temperature meter TESTO 901	Agilent Testoterm	942 TESTO
Abnormal heat and fire	Glow-wire test device with measuring equipment	Friborg	GLOW
Mechanical strength of terminals	Test equipment	AIT	MSD
Insertability of unprepared conductors	Test gauge	AIT	Gauge 1...16
Strength of actuator mechanism	Test equipment	Sauter GmbH	FH1K
Degree of protection	Test probe, dust chamber Test equipment for ingress of water	PTL, Friborg PTL, Friborg	PTL1...3, DUST X1...X4
Clearances, creepage distances	Digital slide gauge	Spiral	SCHUB-1



Test Report issued under the responsibility of:



**TEST REPORT**  
**IEC 60947-3**  
**Low-voltage switchgear and controlgear**  
**Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units**

**Report Number** .....: 2.03.02769.1.0/EFD8/CB  
**Date of issue** .....: 17.04.2014  
**Total number of pages**.....: 70

**CB Testing Laboratory**.....: AIT Austrian Institute of Technology GmbH  
**Address** .....: 1210 Vienna, Giefinggase 2, AUSTRIA

**Applicant's name**.....: ETI Elektroelement d.d.  
**Address** .....: 1411 Izlake, Obrezija 5, SLOVENIA

**Test specification:**  
**Standard** .....: IEC 60947-3:2008 (Third Edition) + A1:2012 in conjunction with IEC 60947-1:2007 (Fifth Edition) + A1:2010  
**Test procedure**.....: CB-Scheme  
**Non-standard test method**.....: N/A

**Test Report Form No.** ....: IEC60947\_3C  
**Test Report Form(s) Originator** ....: OVE  
**Master TRF** .....: Dated 2013-05




**Copyright © 2013 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.**

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

**This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.**

**Test item description** .....: Fuse-switch-disconnectors for cylindrical fuse-links 8x31  
**Trade Mark** .....: ETI  
**Manufacturer**.....: ETI Elektroelement d.d.  
**Model/Type reference** .....: EFD 8  
**Ratings** .....: 400V / up to 20A (with gG) / 50/60Hz / 1p up to 3p+N  
400V / up to 10A (with aM) / 50/60Hz / 1p up to 3p+N

<b>Testing procedure and testing location:</b>	
<input checked="" type="checkbox"/> <b>CB/CCA Testing Laboratory:</b>	
Testing location/ address .....	AIT Austrian Institute of Technology GmbH 1210, Vienna, Giefinggasse 2, AUSTRIA
<input type="checkbox"/> <b>Associated CB Laboratory:</b>	
Testing location/ address .....	---
Tested by (name + signature) ..:	Ing.J.Ainetter 
Approved by (+ signature).....:	Ing.K.Farhofer 
	
<input type="checkbox"/> <b>Testing procedure: TMP</b>	
Tested by (name + signature) ..:	---
Approved by (+ signature).....:	---
Testing location/ address .....	---
<input type="checkbox"/> <b>Testing procedure: WMT</b>	
Tested by (name + signature) ..:	---
Witnessed by (+ signature) .....	---
Approved by (+ signature).....:	---
Testing location/ address .....	---
<input type="checkbox"/> <b>Testing procedure: SMT</b>	
Tested by (name + signature) ..:	---
Approved by (+ signature).....:	---
Supervised by (+ signature).....:	---
Testing location/ address .....	---
<input type="checkbox"/> <b>Testing procedure: RMT</b>	
Tested by (name + signature) ..:	---
Approved by (+ signature).....:	---
Supervised by (+ signature).....:	---
Testing location/ address .....	---

**List of Attachments:**

---

**Summary of testing:****Tests performed:**

A type test was performed according to

- IEC 60947-1:2011 (Edition 5.1)
- IEC 60947-3:2012 (Edition 3.1)

The fuse-switch-disconnectors  
for cylindrical fuse-links 8x31

- EFD 8

have passed the type test successfully.

**Testing location:**

AIT Austrian Institute of Technology GmbH  
Business Unit Electric Energy Systems  
Power Service Center  
Giefinggasse 2  
1210 Vienna  
AUSTRIA



The AIT Austrian Institute of Technology GmbH is a  
recognized CB/CCA Testing Laboratory under the  
responsibility of OVE as the National Certification  
Body.

**Summary of compliance with National Differences:**

---



Copy of marking plate:



**Test item particulars:**

- method of operation .....: Dependent manual operation
- suitability for isolation .....: Suitable for isolation
- degree of protection .....: IP20
- number of poles .....: 1p, 1p+N, 2p, 3p, 3p+N
- kind of current .....: AC
- in the case of a.c., number of phases and  
rated frequency .....: 1 up to 3 / 50/60Hz
- number of positions of the main contacts .....: 2 (O / I)
- breaking arrangement for fused devices .....: Double break

## Rated and limiting values, main circuit:

- rated operational voltage  $U_e$  (V) .....: 400
- rated insulation voltage  $U_i$  (V) .....: 690
- rated impulse withstand voltage  $U_{imp}$  (kV) .....: 8
- conventional free air thermal current  $I_{th}$  (A) .....: 20 (2,3W max. with gG fuse-links)  
10 (0,6W max. with aM fuse-links)
- conventional enclosed thermal current  $I_{the}$  (A) .....: -
- rated operational current  $I_e$  (A) .....: 20 (with gG fuse-links)  
10 (with aM fuse-links)
- rated uninterrupted current  $I_U$  (A) .....: 20 (2,3W max. with gG fuse-links)  
10 (0,6W max. with aM fuse-links)
- rated frequency (Hz) .....: 50/60
- utilization category .....: AC-22B at 400V/20A

## Short-circuit characteristic:

- rated short-time withstand current  $I_{cw}$  (kA) .....: 240A / 1s
- rated short-time making capacity  $I_{cm}$  (kA) .....: -
- rated conditional short-circuit current .....: 100kA (with 20A gG fuse-links)  
50kA (with 10A aM fuse-links)

Control circuits .....: -

Auxiliary circuits .....: -

Relays and releases .....: -

## Co-ordination with short-circuit protective devices:

- kind of protective device .....: Cylindrical fuse-links 8x31, up to 20A (gG)  
Cylindrical fuse-links 8x31, up to 10A (aM)

**Possible test case verdicts:**

- test case does not apply to the test object .....: N/A
- test object does meet the requirement .....: P (Pass)
- test object does not meet the requirement .....: F (Fail)

**Testing:**

Date of receipt of test item .....: 10/2008 and 02/2014

Date (s) of performance of tests .....: 10/2008 to 12/2008 and 02/2014 to 03/2014

**General remarks:**

The test results presented in this report relate only to the object tested.  
This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a  comma /  point is used as the decimal separator.

**Manufacturer's Declaration per sub-clause 4.2.5 of IEC 60947-2:**

The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided .....:  **Yes**  
 **Not applicable**

**When differences exist; they shall be identified in the General product information section.**

**Name and address of factory (ies)..... :** ETI Elektroelement d.d.  
Obrezija 5  
1411 Izlake  
SLOVENIA

**General product information:**

Low voltage  
fuse-switch-disconnectors  
for cylindrical fuse-links 8x31

type

**EFD 8**

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
5.2	MARKING		
	Marking on equipment itself or on nameplate or nameplates attached to the equipment and legible from the front after mounting		P
	- indication of the open and closed position	O / I	P
	- suitability for isolation	In the open position (O)	P
	- disconnectors AC-20 and DC-20 only: marked "Do not operate under load"		N/A
	Following marking is visible after mounting:		
	- direction of movement of the actuator (see 7.1.5.2)	Up / Down	P
	- indication of the position of the actuator (see also 7.1.6.1 and 7.1.6.2)	O / I	P
	- approval or certification mark, if applicable		N/A
	- for miniaturized equipment, symbol, colour code or letter code		N/A
	- terminal identification and marking (see 7.1.8.4)		P
	- IP code and class of protection against electric shock, when applicable (marked preferably on the equipment as far as possible)		N/A
	- suitability for isolation, where applicable, with the isolation function symbol according to IEC 60617-7, reference 07-01-03, combined with the appropriate function symbol for the equipment		P
	- this symbols clearly and unmistakably marked		P
	- this symbols are visible when the equipment is installed as in service and the actuator is accessible		P
	In the case of electronically controlled electromagnets, information other than that given in 5.1 may also be necessary (see also 4.5 and Annex U)		N/A
	The indication "s", "sol", "r" or "f" for non-universal screwless terminals shall be marked on the device or, if the space available is not sufficient, on the smallest package unit or in technical information provided with the product		N/A
	Marking on equipment not needed to be visible after mounting:		
	- manufacturer's name or trademark	ETI	P
	- type designation or serial number	EFD 8	P
	- rated operational currents or powers	20A gG 10A aM	P
	- rated operational voltages	400V~	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	- utilization category	AC-22B	P
	- rated frequency or the indication "DC"	50/60Hz	P
	- manufacturer's claim for compliance with IEC 60947-3	IEC 60947-1 IEC 60947-3	P
	- degree of protection	IP20	P
	Marking on fuse-combination units:		P
	- fuse type	8 x 31	P
	- maximum rated current	20A gG 10A aM	P
	- power loss of the fuse-link	≤ 2,3W (gG) ≤ 0,6W (aM)	P
	Identification of terminals:		P
	- line terminals, unless connection is immaterial		P
	- load terminals, unless connection is immaterial		P
	- neutral pole terminal		P
	- protective earth terminal		N/A
	Data in the manufacturer's published information:		P
	- rated insulation voltage	690V	P
	- rated impulse withstand voltage for equipment suitable for isolation or when determined	8kV	P
	- pollution degree, if different from 3	3	P
	- rated duty	Uninterrupted duty	P
	- rated short-time withstand current and duration	240A / 1s	P
	- rated short-circuit making capacity	-	N/A
	- rated conditional short-circuit current	100kA (with 20A/gG) 50kA (with 10A/aM)	P
5.3	Instructions for installation, operation and maintenance		P
6	NORMAL SERVICE, MOUNTING AND TRANSPORT CONDITIONS		
6.1	Normal service conditions		P
6.1.1	Ambient air temperature		P
6.1.2	Altitude		P
6.1.3	Atmospheric conditions		P
6.1.3.1	Humidity		P
6.1.3.2	Pollution degree		P
6.1.4	Shock and vibration		P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
6.2	Conditions during transport and storage		P
6.3	Mounting		P
7	CONSTRUCTIONAL AND PERFORMANCE REQUIREMENTS		
7.1	Constructional requirements		
7.1.1	General		
7.1.2	Materials		
7.1.2.1	General material requirements		
	Parts of insulating materials which might be exposed to thermal stresses due to electrical effects within the equipment shall not be adversely affected by abnormal heat and by fire.		P
	The manufacturer specifies which test method, 7.1.2.2 or 7.1.2.3, is to be used .....	Test method acc. to 7.1.2.2	
7.1.2.2	Glow wire Testing		
	The suitability of materials used is verified by making tests on .....	Sections taken from the equipment	P
	or		
	- providing data from the insulating material supplier fulfilling the requirements according to IEC 60695-2-12		N/A
	Glow-wire test according to IEC 60695-2-10 and IEC 60695-2-11		—
	Parts made of insulating material necessary to retain current-carrying parts in position: test temperature 960 °C		P
	No visible flame and no sustained glowing		N/A
	Flames and glowing extinguish within 30 s	Extinguishing within 2s	P
	No ignition of the tissue paper		P
	Parts of insulating material not necessary to retain current-carrying parts in position, even though in contact with them: test temperature 650 °C		
	No visible flame and no sustained glowing	No visible flame	P
	Flames and glowing extinguish within 30 s		N/A
	No ignition of the tissue paper		P
7.1.2.3	Test based on flammability category		
	For parts of insulating materials, hot wire ignition and, where applicable, arc ignition tests as specified in 8.2.1.1.2, shall be made based on flammability category		N/A
	Tests on materials are made in accordance with Annex M		N/A

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	The hot wire ignition (HWI) and arc ignition (AI) test value requirements related to the material flammability category shall conform to Table M.1 or M.2		N/A
	Alternatively, the manufacturer may provide data from the insulating material supplier fulfilling the requirements given in Annex M		N/A
7.1.3	Current-carrying parts and their connections		P
	Current-carrying parts have the necessary mechanical strength and current-carrying capacity for their intended use		P
	For electrical connections, no contact pressure is transmitted through insulating material other than ceramic or other material with characteristics not less suitable, unless there is sufficient resiliency in the metallic parts to compensate for any possible shrinkage or yielding of the insulation material		P
7.1.4	Clearances .....	See appended table 7.1.4	P
	Creepage distances .....	See appended table 7.1.4	P
	Pollution degree .....	2	—
	Comparative tracking index (V) .....	450	—
	Material group .....	II	—
7.1.5	Actuator		P
7.1.5.1	Insulation		—
	Actuator insulated from live parts for		—
	- rated insulation voltage	690V	P
	- rated impulse withstand voltage	8kV	P
	Actuator made of metal	No	—
	- connected to a protective conductor or provided with an additional insulation		N/A
	Actuator made of or covered by insulating material:	Made of insulating material	—
	- internal metal parts, which might become accessible in the event of an insulation failure, are also insulated from live parts for the rated insulation voltage		P
7.1.5.2	Direction of movement		P
	The direction of operation for actuators shall where applicable conform to IEC 60447		P
	There is no doubt of the "I" and "O" position and the direction of operation		P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
7.1.6	Indication of contact position		
7.1.6.1	Indicating means	Actuator	P
7.1.6.2	Indication by the actuator		P
7.1.7	Additional safety requirements for equipment suitable for isolation		
7.1.7.1	Additional constructional requirements		
	- marking according to 5.2.1b		P
	- indication of the position of the contacts	Yes	P
	- construction of the actuating mechanism	See 7.1.5.2	P
	- minimum clearances across open contacts (see Table 13, Part 1) (mm) .....	8	—
	- measured clearances (mm) .....	> 8	P
	- test Uimp across gap (kV) .....	12,3	P
7.1.7.2	Supplementary requirements for equipment with provision for electrical interlocking with contactors or circuit-breakers:		N/A
	Auxiliary switch is rated according to IEC 60947-5-1 (unless the equipment is rated AC-23)		N/A
	Time interval between opening of the contacts of the auxiliary contact and the contacts of the main poles: $\geq 20$ ms .....	-	—
	Measured time interval (ms) .....	-	N/A
	During the closing operation the contacts of the auxiliary switch closes after or simultaneously with the contacts of the main poles		N/A
7.1.7.3	Supplementary requirements for equipment provided with means for padlocking the open position:		
	The locking means is so designed that it cannot be removed with the appropriate padlock(s) installed		N/A
	Test force F applied to the actuator in an attempt to operate to the closed position (N) .....	-	—
	Rated impulse withstand voltage (kV) .....	-	—
	Test Uimp on open main contacts at the test force		N/A
7.1.8	Terminals		
7.1.8.1	All parts of terminals which maintain contact and carry current are of metal having adequate mechanical strength	(see 8.2.4 below)	P
	Terminal connections are such that necessary contact pressure is maintained	(see 8.2.4 below)	P



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Terminals are so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal	(see 8.2.4 below)	P
	Terminals do not allow the conductor to be displaced or to be displaced themselves in a manner detrimental to the operator of equipment and the insulation voltage is not reduced below the rated value	(see 8.2.4 below)	P
	Screwless-type clamping units, unless otherwise specified by the manufacturer, shall accept rigid and flexible conductors as indicated in Table 1		N/A
	On screwless-type clamping unit, the connection or disconnection of conductors shall be made as follows:		
	– on universal clamping units by the use of a general purpose tool or a convenient device, integral with the clamping unit to open it for the insertion or withdrawal of the conductors		N/A
	– on push-wire clamping units by simple insertion. For the disconnection of the conductors an operation other than a pull only on the conductor shall be necessary. The use of a general purpose tool or of a convenient device, integral with the clamping unit is allowed in order to "open" it and to assist the insertion or the withdrawal of the conductor		N/A
8.2.4	Mechanical properties of terminals		
	Mechanical strength of terminals		P
	Maximum cross-sectional area of conductor (mm <sup>2</sup> ) .....	10	—
	Diameter of thread (mm) .....	M5	—
	Torque (Nm) .....	2 (acc. to manufacturers instruction)	—
	5 times on 2 separate clamping units		P
	Testing for damage to and accidental loosening of conductor (flexion test)		
	Conductor of the smallest cross-sectional area (mm <sup>2</sup> ) .....	1,5	—
	Number of conductor of the smallest cross section .....	1	—
	Diameter of bushing hole (mm) .....	6,5	—
	Height between the equipment and the platen .....	260	—
	Mass at the conductor(s) (kg) .....	0,4	—
	135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit		P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Pull-out test		
	Force (N), applied for 1 min. ....:	40	—
	During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit		P
	Conductor of the largest cross-sectional area (mm <sup>2</sup> ) .....	2,5	—
	Number of conductor of the largest cross section .....	1	—
	Diameter of bushing hole (mm) .....	9,5	—
	Height between the equipment and the platen .....	280	—
	Mass at the conductor(s) (kg) .....	0,7	—
	135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit		P
	Pull-out test		
	Force (N), applied for 1 min. ....:	50	—
	During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit		P
	Conductor of the largest and smallest cross-sectional area (mm <sup>2</sup> ) .....	-	—
	Number of conductor of the smallest cross section, number of conductor of the largest cross section .....	-	—
	Diameter of bushing hole (mm) .....	-	—
	Height between the equipment and the platen .....	-	—
	Mass at the conductor(s) (kg) .....	-	—
	135 continuous revolutions: the conductor neither slips out of the terminal nor breaks near the clamping unit		N/A
	Pull-out test		
	Force (N), applied for 1 min. ....:	-	—
	During the test, the conductor neither slips out of the terminal nor breaks near the clamping unit		N/A
7.1.8.2	Connection capacity		
	Type of conductors .....	Copper, rigid or flexible	—
	Minimum cross-sectional area of conductor (mm <sup>2</sup> ) .....	1,5	—
	Maximum cross-sectional area of conductor (mm <sup>2</sup> ) .....	10	—
	Number of conductors simultaneously connectable to the terminal .....	1	—

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
7.1.8.3	Connection		
	Terminals for connection to external conductors are readily accessible during installation		P
	Clamping screws and nuts do not serve to fix any other component		P
7.1.8.4	Terminal identification and marking		
	Terminal intended exclusively for the neutral conductor		P
	Protective earth terminal		N/A
	Other terminals		P
7.1.9	Additional requirements for equipment provided with a neutral pole		
	Equipment provided with a pole intended for the connection of neutral, this pole shall be clearly marked by the letter "N"		P
	The switched neutral pole does not break before and does not make after the other poles except		P
	- a pole having the appropriate short-circuit breaking and making capacity is used as neutral pole, all poles may operate together		P
	Conventional thermal current of neutral pole	20A	P
7.1.10	Provisions for protective earthing		
7.1.10.1	The exposed conductive parts are electrically interconnected and connected to a protective earth terminal		N/A
7.1.10.2	Protective earth terminal is readily accessible		N/A
	Protective earth terminal is suitably protected against corrosion		N/A
	Electrical continuity between the exposed conductive parts of the protective earth terminal and the metal sheathing of connecting conductors		N/A
	Protective earth terminal has no other functions		N/A
7.1.10.3	Protective earth terminal marking and identification		N/A
7.1.11	Enclosure for equipment		
7.1.11.1	Design		
	When the enclosure is opened, all parts requiring access for installation and maintenance are readily accessible		N/A
	Sufficient space is provided inside the enclosure		N/A

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	The fixed parts of a metal enclosure are electrically connected to the other exposed conductive parts of the equipment and connected to a terminal which enables them to be earthed or connected to a protective conductor		N/A
	Under no circumstances a removable metal part of the enclosure is insulated from the part carrying the earth terminal when the removable part is in place		N/A
	The removable parts of the enclosure are firmly secured to the fixed parts by a device such that they cannot be accidentally loosened or detached owing to the effects of operation of the equipment or vibrations		N/A
	When an enclosure is so designed as to allow the covers to be opened without the use of tools, means is provided to prevent loss of the fastening devices		N/A
	If the enclosure is used for mounting push-buttons, it is not possible to remove the buttons from the outside of the enclosure		N/A
7.1.11.2	Insulation		
	If, in order to prevent accidental contact between a metallic enclosure and live parts, the enclosure is partly or completely lined with insulating material, then this lining is securely fixed to the enclosure		N/A
7.1.12	Degree of protection of enclosed equipment		
	Degree of protection .....	IP20	P
7.1.13	Conduit pull-out, torque and bending with metallic conduits		
	Withstand the stress occurring during its installation .....	-	N/A

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3	TEST SEQUENCE I: GENERAL PERFORMANCE CHARACTERISTICS		
8.3.3.1	Temperature-rise		P
	<b>EFD 8, 1p</b>		
	ambient temperature 10-40 °C .....	22,5	—
	test enclosure W x H x D (mm x mm x mm) .....	-	—
	material of enclosure .....	-	—
	Main circuits, test conditions:		P
	- rated operational current I <sub>e</sub> (A) .....	20	—
	- cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) ...:	2,5 / 1000	—
	Fuse-link details (fuse-combination units only):		P
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	Measured temperature-rise .....	See appended table 8.3.3.1	P
	Auxiliary circuits, test conditions:		N/A
	- rated operation current (A) .....	-	—
	- cable cross-section (mm <sup>2</sup> ) .....	-	—
	Measured temperature-rise .....	-	

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.1	Temperature-rise		P
	<b>EFD 8, 2p</b>		
	ambient temperature 10-40 °C .....	23	—
	test enclosure W x H x D (mm x mm x mm) .....	-	—
	material of enclosure .....	-	—
	Main circuits, test conditions:		P
	- rated operational current I <sub>e</sub> (A) .....	20	—
	- cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) ...:	2,5 / 1000	—
	Fuse-link details (fuse-combination units only):		P
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	Measured temperature-rise .....	See appended table 8.3.3.1	P
	Auxiliary circuits, test conditions:		N/A
	- rated operation current (A) .....	-	—
	- cable cross-section (mm <sup>2</sup> ) .....	-	—
	Measured temperature-rise .....	-	

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.1	Temperature-rise		P
	<b>EFD 8, 3p+N</b>		
	ambient temperature 10-40 °C .....	23	—
	test enclosure W x H x D (mm x mm x mm) .....	-	—
	material of enclosure .....	-	—
	Main circuits, test conditions:		P
	- rated operational current I <sub>e</sub> (A) .....	20	—
	- cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) ...:	2,5 / 1000	—
	Fuse-link details (fuse-combination units only):		P
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	Measured temperature-rise .....	See appended table 8.3.3.1	P
	Auxiliary circuits, test conditions:		N/A
	- rated operation current (A) .....	-	—
	- cable cross-section (mm <sup>2</sup> ) .....	-	—
	Measured temperature-rise .....	-	N/A

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.3.2	Test of dielectric properties		P
	<b>EFD 8, 1p</b>		
	Rated impulse withstand voltage (kV) .....	8	—
	- test Uimp main circuits (kV) .....	9,8	P
	- test Uimp auxiliary circuits (kV) .....	-	N/A
	- test Uimp on open main contacts (equipment suitable for isolation) (kV) .....	12,3	P
	Power-frequency withstand voltage (V) .....	690	—
	- main circuits, test voltage for 5 sec. (V) .....	1890	P
	- control and auxiliary circuits, test voltage for 5 sec. (V) .....	-	N/A
	Devices, which have been disconnected for the power-frequency withstand voltage test.....	-	N/A
	Equipment suitable for isolation, leakage current not exceed 0,5 mA		—
	Test voltage 1,1 Ue (V) .....	440	—
	Measured leakage current (mA).....	< 0,1	P

8.3.3.2	Test of dielectric properties		P
	<b>EFD 8, 3p+N</b>		
	Rated impulse withstand voltage (kV) .....	8	—
	- test Uimp main circuits (kV) .....	9,8	P
	- test Uimp auxiliary circuits (kV) .....	-	N/A
	- test Uimp on open main contacts (equipment suitable for isolation) (kV) .....	12,3	P
	Power-frequency withstand voltage (V) .....	690	—
	- main circuits, test voltage for 5 sec. (V) .....	1890	P
	- control and auxiliary circuits, test voltage for 5 sec. (V) .....	-	N/A
	Devices, which have been disconnected for the power-frequency withstand voltage test.....	-	N/A
	Equipment suitable for isolation, leakage current not exceed 0,5 mA		—
	Test voltage 1,1 Ue (V) .....	440	—
	Measured leakage current (mA).....	< 0,1	P



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.3	Making and breaking capacity		P
	<b>EFD 8, 1p: AC-22B at 400V/20A</b>		
	- utilization category .....	AC-22B	—
	- rated operational voltage $U_e$ (V) .....	400	—
	- rated operational current $I_e$ (A) or power (kW) .....	20A	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	Conditions for make operations, AC-23A and AC-23B only:		N/A
	- test voltage, $U = 1,05 U_e$ .....(V):	L1: - L2: - L3: -	—
	- test current, $I =$ ..... x $I_e$ (A):	L1: - L2: - L3: -	—
	- power factor .....	L1: - L2: - L3: -	—
	Conditions for break operations, AC-23A and AC-23B only:		N/A
	- test voltage, $U = 1,05 U_e$ .....(V):	L1: - L2: - L3: -	—
	- test current, $I =$ ..... x $I_e$ (A):	L1: - L2: - L3: -	—
	- power factor .....	L1: - L2: - L3: -	—
	Conditions for make/break operations, other than AC-23A and AC-23B:		P
	- test voltage, $U = 1,05 U_e$ .....(V):	L1: 423 L2: - L3: -	—
	- test current, $I =$ ..... 3 $I_e$ (A):	L1: 63 L2: - L3: -	—
	- power factor/ time constant .....	L1: 0,64 L2: - L3: -	—

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Number of make/break or make and break operations .....	5	P
	- recovery voltage duration ( $\geq 50$ ms) (ms) .....	Permanent	P
	- current duration (ms) .....	290	—
	- time interval between operations .....	30	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		P
	- oscillatory frequency (kHz) .....	37,58	—
	- measured oscillatory frequency (kHz) .....	L1: 37,7 L2: - L3: -	P
	- factor $\gamma$ .....	L1: 1,1 L2: - L3: -	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.3.4	Dielectric verification		
	test voltage $2*U_e$ with a minimum of 1000V~ (V) .....	1000	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole .....	-	N/A
	Leakage current (mA) (other utilization categories): $\leq 2$ mA/pole) .....	< 1	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	- conductor cross-section (mm <sup>2</sup> ) .....	2,5	—
	- test current I <sub>e</sub> (A) .....	20	—
	Measured temperature-rise .....	See appended table 8.3.3.6	P
8.3.3.7	Strength of actuator mechanism		P
8.2.5	Verification of the strength of actuator mechanism and position indicating device		P
	- actuator type (fig.) .....	1b	—
8.2.5.2.1	Dependent and independent manual operation		P
	- actuating force for opening (N) .....	18	—
	- test force with blocked main contacts (N) .....	55	—
	- used method to keep the contact closed .....	Brazing	—
	During and after the test, open position not indicated .....	No open position	P
	Equipment with locking mean, no locking in the open position while test force is applied .....	No locking mechanism	P
8.2.5.2.2	Dependent power operation		N/A
	- main contacts fixed together in the closed position .....	-	N/A
	- used method to keep the contact closed .....	-	N/A
	- 110% of the rated supply voltage applied to the equipment (3 times) .....	-	N/A
	During and after the test, open position not indicated .....	-	N/A
	Equipment show no damage impairing its normal operation.....	-	N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....	-	N/A

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position .....	-	N/A
	- used method to keep the contact closed .....	-	N/A
	- stored energy of the power operator released (3 times).....	-	N/A
	During and after the test, open position not indicated .....	-	N/A
	Equipment show no damage impairing its normal operation.....	-	N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....	-	N/A

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.3	Making and breaking capacity		P
	<b>EFD 8, 2p: AC-22B at 400V/20A</b>		
	- utilization category .....	AC-22B	—
	- rated operational voltage U <sub>e</sub> (V) .....	400	—
	- rated operational current I <sub>e</sub> (A) or power (kW) .....	20A	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	Conditions for make operations, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 U <sub>e</sub> .....(V):	L1: - L2: - L3: -	—
	- test current, I = ..... x I <sub>e</sub> (A):	L1: - L2: - L3: -	—
	- power factor .....	L1: - L2: - L3: -	—
	Conditions for break operations, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 U <sub>e</sub> .....(V):	L1: - L2: - L3: -	—
	- test current, I = ..... x I <sub>e</sub> (A):	L1: - L2: - L3: -	—
	- power factor .....	L1: - L2: - L3: -	—
	Conditions for make/break operations, other than AC-23A and AC-23B:		P
	- test voltage, U = 1,05 U <sub>e</sub> .....(V):	L1: 424 L2: 424 L3: -	—
	- test current, I = ..... 3 I <sub>e</sub> (A):	L1: 62,5 L2: 62,5 L3: -	—
	- power factor/ time constant .....	L1: 0,67 L2: 0,67 L3: -	—

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Number of make/break or make and break operations .....	5	P
	- recovery voltage duration ( $\geq 50$ ms) (ms) .....	Permanent	P
	- current duration (ms) .....	290	—
	- time interval between operations .....	30	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		P
	- oscillatory frequency (kHz) .....	37,58	—
	- measured oscillatory frequency (kHz) .....	L1: 37,7 L2: 37,7 L3: -	P
	- factor $\gamma$ .....	L1: 1,1 L2: 1,1 L3: -	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.3.4	Dielectric verification		
	test voltage $2*U_e$ with a minimum of 1000V~ (V) .....	1000	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole .....	-	N/A
	Leakage current (mA) (other utilization categories): $\leq 2$ mA/pole) .....	< 1	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	- conductor cross-section (mm <sup>2</sup> ) .....	2,5	—
	- test current I <sub>e</sub> (A) .....	20	—
	Measured temperature-rise .....	See appended table 8.3.3.6	P
8.3.3.7	Strength of actuator mechanism		P
8.2.5	Verification of the strength of actuator mechanism and position indicating device		P
	- actuator type (fig.) .....	1b	—
8.2.5.2.1	Dependent and independent manual operation		P
	- actuating force for opening (N) .....	20	—
	- test force with blocked main contacts (N) .....	60	—
	- used method to keep the contact closed .....	Brazing	—
	During and after the test, open position not indicated .....	No open position	P
	Equipment with locking mean, no locking in the open position while test force is applied .....	No locking mechanism	P
8.2.5.2.2	Dependent power operation		N/A
	- main contacts fixed together in the closed position .....	-	N/A
	- used method to keep the contact closed .....	-	N/A
	- 110% of the rated supply voltage applied to the equipment (3 times) .....	-	N/A
	During and after the test, open position not indicated .....	-	N/A
	Equipment show no damage impairing its normal operation.....	-	N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....	-	N/A

<b>IEC 60947-3</b>			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position .....	-	N/A
	- used method to keep the contact closed .....	-	N/A
	- stored energy of the power operator released (3 times).....	-	N/A
	During and after the test, open position not indicated .....	-	N/A
	Equipment show no damage impairing its normal operation.....	-	N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....	-	N/A



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.3	Making and breaking capacity		P
	<b>EFD 8, 3p+N: AC-22B at 400V/20A</b>		
	- utilization category .....	AC-22B	—
	- rated operational voltage Ue (V) .....	400	—
	- rated operational current Ie (A) or power (kW) .....	20A	—
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	Conditions for make operations, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue .....	L1: - L2: - L3: -	—
	- test current, I = ..... x Ie (A):	L1: - L2: - L3: -	—
	- power factor .....	L1: - L2: - L3: -	—
	Conditions for break operations, AC-23A and AC-23B only:		N/A
	- test voltage, U = 1,05 Ue .....	L1: - L2: - L3: -	—
	- test current, I = ..... x Ie (A):	L1: - L2: - L3: -	—
	- power factor .....	L1: - L2: - L3: -	—
	Conditions for make/break operations, other than AC-23A and AC-23B:		P
	- test voltage, U = 1,05 Ue .....	L1: 422 L2: 423 L3: 422	—
	- test current, I = ..... 3 Ie (A):	L1: 62,5 L2: 63,0 L3: 62,0	—
	- power factor/ time constant .....	L1: 0,65 L2: 0,65 L3: 0,66	—

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Number of make/break or make and break operations .....	5	P
	- recovery voltage duration ( $\geq 50$ ms) (ms) .....	Permanent	P
	- current duration (ms) .....	290	—
	- time interval between operations .....	30	P
	Characteristic of transient recovery voltage for AC-22 and AC-23 only		P
	- oscillatory frequency (kHz) .....	37,58	—
	- measured oscillatory frequency (kHz) .....	L1: 37,7 L2: 37,7 L3: 37,7	P
	- factor $\gamma$ .....	L1: 1,1 L2: 1,1 L3: 1,1	P
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.3.3.6	Condition of the equipment after making and breaking capacity test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.3.4	Dielectric verification		
	test voltage $2 \cdot U_e$ with a minimum of 1000V~ (V) .....	1000	—
	No flashover or breakdown		P
8.3.3.5	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole .....	-	N/A
	Leakage current (mA) (other utilization categories): $\leq 2$ mA/pole) .....	< 1	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.6	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	- conductor cross-section (mm <sup>2</sup> ) .....	2,5	—
	- test current I <sub>e</sub> (A) .....	20	—
	Measured temperature-rise .....	See appended table 8.3.3.6	P
8.3.3.7	Strength of actuator mechanism		P
8.2.5	Verification of the strength of actuator mechanism and position indicating device		P
	- actuator type (fig.) .....	1b	—
8.2.5.2.1	Dependent and independent manual operation		P
	- actuating force for opening (N) .....	25	—
	- test force with blocked main contacts (N) .....	75	—
	- used method to keep the contact closed .....	Brazing	—
	During and after the test, open position not indicated .....	No open position	P
	Equipment with locking mean, no locking in the open position while test force is applied .....	No locking mechanism	P
8.2.5.2.2	Dependent power operation		N/A
	- main contacts fixed together in the closed position .....	-	N/A
	- used method to keep the contact closed .....	-	N/A
	- 110% of the rated supply voltage applied to the equipment (3 times) .....	-	N/A
	During and after the test, open position not indicated .....	-	N/A
	Equipment show no damage impairing its normal operation.....	-	N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....	-	N/A

<b>IEC 60947-3</b>			
Clause	Requirement + Test	Result - Remark	Verdict
8.2.5.2.3	Independent power operation		N/A
	- main contacts fixed together in the closed position .....	-	N/A
	- used method to keep the contact closed .....	-	N/A
	- stored energy of the power operator released (3 times).....	-	N/A
	During and after the test, open position not indicated .....	-	N/A
	Equipment show no damage impairing its normal operation.....	-	N/A
	Equipment with locking mean, no locking in the open position while test force is applied .....	-	N/A

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4	TEST SEQUENCE II: OPERATIONAL PERFORMANCE CAPABILITY		
8.3.4.1	Operational performance test		P
	<b>EFD 8, 1p: AC-22B at 400V/20A</b>		
	- utilization category .....	AC-22B	—
	- rated operational voltage (V) .....	400	—
	- rated operational current (A) .....	20	—
	Test conditions for electrical operation cycles:		
	- test voltage (V) .....	L1: 405 L2: - L3: -	—
	- test current (A) .....	L1: 21,5 L2: - L3: -	—
	- power factor/time constant .....	L1: 0,79 L2: - L3: -	—
	Number of cycles with current .....	300	P
	Number of cycles without current .....	1700	P
	First test sequence (with/without current) .....	With	—
	Second test sequence (with/without current) .....	Without	—
	- time interval between first and second test sequence .....	10min	—
	- current duration (ms) .....	290	P
	- time interval between operations (s) .....	30	P
8.3.4.1.5	Behaviour of the equipment during operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.4.1.6	Condition of the equipment after operation performance capability test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	- equipment is able to carry its rated current after normal closing operation		P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.2	Dielectric verification		P
	test voltage $2 \cdot U_e$ with a minimum of 1000V~ (V) .....	1000	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....	-	N/A
	Leakage current (mA) (other utilization categories) $\leq 2$ mA/pole .....	< 1	P
8.3.4.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	- conductor cross-section (mm <sup>2</sup> ) .....	2,5	—
	- test current $I_e$ (A) .....	20	—
	Measured temperature-rise .....	See appended table 8.3.4.4	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1	Operational performance test		P
	<b>EFD 8, 2p: AC-22B at 400V/20A</b>		
	- utilization category .....	AC-22B	—
	- rated operational voltage (V) .....	400	—
	- rated operational current (A) .....	20	—
	Test conditions for electrical operation cycles:		
	- test voltage (V) .....	L1: 404 L2: 404 L3: -	—
	- test current (A) .....	L1: 22 L2: 22 L3: -	—
	- power factor/time constant .....	L1: 0,82 L2: 0,82 L3: -	—
	Number of cycles with current .....	300	P
	Number of cycles without current .....	1700	P
	First test sequence (with/without current) .....	With	—
	Second test sequence (with/without current) .....	Without	—
	- time interval between first and second test sequence .....	10min	—
	- current duration (ms) .....	290	P
	- time interval between operations (s) .....	30	P
8.3.4.1.5	Behaviour of the equipment during operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.4.1.6	Condition of the equipment after operation performance capability test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	- equipment is able to carry its rated current after normal closing operation		P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.2	Dielectric verification		P
	test voltage $2 \cdot U_e$ with a minimum of 1000V~ (V) .....	1000	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....	-	N/A
	Leakage current (mA) (other utilization categories) $\leq 2$ mA/pole .....	< 1	P
8.3.4.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	- conductor cross-section (mm <sup>2</sup> ) .....	2,5	—
	- test current $I_e$ (A) .....	20	—
	Measured temperature-rise .....	See appended table 8.3.4.4	P



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.1	Operational performance test		P
	<b>EFD 8, 3p+N: AC-22B at 400V/20A</b>		
	- utilization category .....	AC-22B	—
	- rated operational voltage (V) .....	400	—
	- rated operational current (A) .....	20	—
	Test conditions for electrical operation cycles:		
	- test voltage (V) .....	L1: 403 L2: 405 L3: 404	—
	- test current (A) .....	L1: 21,5 L2: 22,0 L3: 21,5	—
	- power factor/time constant .....	L1: 0,78 L2: 0,78 L3: 0,78	—
	Number of cycles with current .....	300	P
	Number of cycles without current .....	1700	P
	First test sequence (with/without current) .....	With	—
	Second test sequence (with/without current) .....	Without	—
	- time interval between first and second test sequence .....	10min	—
	- current duration (ms) .....	300	P
	- time interval between operations (s) .....	30	P
8.3.4.1.5	Behaviour of the equipment during operational performance test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.4.1.6	Condition of the equipment after operation performance capability test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	- equipment is able to carry its rated current after normal closing operation		P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.4.2	Dielectric verification		P
	test voltage $2 \cdot U_e$ with a minimum of 1000V~ (V) .....	1000	—
	No breakdown or flashover		P
8.3.4.3	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....	440	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....	-	N/A
	Leakage current (mA) (other utilization categories) $\leq 2$ mA/pole .....	< 1	P
8.3.4.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	- conductor cross-section (mm <sup>2</sup> ) .....	2,5	—
	- test current $I_e$ (A) .....	20	—
	Measured temperature-rise .....	See appended table 8.3.4.4	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5	TEST SEQUENCE III: SHORT-CIRCUIT PERFORMANCE CAPABILITY		
8.3.5.1	Short-time withstand current test		P
	<b>EFD 8, 1p: 240A/1s</b>		
	Rated short-time withstand current I <sub>cw</sub> (A) (≥ 12 I <sub>e</sub> max) .....	240 / 1s	P
	test voltage (V) .....	L1: 403 L2: - L3: -	—
	r.m.s. test current (A) .....	L1: 244 L2: - L3: -	—
	peak test current (A) .....	L1: 347 L2: - L3: -	—
	power factor/time constant .....	L1: 0,94 L2: - L3: -	—
	test duration (ms) .....	1010	—
8.3.5.1.5	Behaviour of the equipment during short-time withstand current test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.5.1.6	Condition of the equipment after short-time withstand current test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	- equipment is able to carry its rated current after normal closing operation		P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5.2	Short-circuit making capacity		N/A
	Rated short-circuit making capacity I <sub>cm</sub> (A) .....	-	N/A
	test voltage (1,05 x U <sub>e</sub> ) .....(V):	L1: - L2: - L3: -	—
	r.m.s. test current (A) .....	L1: - L2: - L3: -	—
	maximum peak test current (A) / factor n .....	-	N/A
	power factor/time constant .....	L1: - L2: - L3: -	N/A
	current duration (ms) .....	-	—
	Time interval between the cycles		—
8.3.5.2.5	Behaviour of the equipment during short-circuit making capacity test		N/A
	Test performed without:		—
	- endanger to the operator		N/A
	-cause damage to adjacent equipment		N/A
	No permanent arcing		N/A
	No flash over between poles and poles and frame		N/A
	No melting of the fuse in the detection circuit		N/A
8.3.5.2.6	Condition of the equipment after short-circuit making capacity test		N/A
	Immediately after the test equipment must work satisfactorily		N/A
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		N/A
	- equipment is able to carry its rated current after normal closing operation		N/A
8.3.5.3	Dielectric verification		P
	test voltage 2*U <sub>e</sub> with a minimum of 1000V~ (V) .....	1000	—
	No flashover or breakdown		P
8.3.5.4	Leakage current		P
	test voltage (1,1x U <sub>e</sub> ) (V) .....	440	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole .....	-	N/A
	Leakage current (mA) (other utilization categories) ≤ 2,0 mA/pole .....	< 1	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	- conductor cross-section (mm <sup>2</sup> ) .....	2,5	—
	- test current I <sub>e</sub> (A) .....	20	—
	Measured temperature-rise .....	See appended table 8.3.5.5	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5.1	Short-time withstand current test		P
	<b>EFD 8, 3p+N: 240A/1s</b>		
	Rated short-time withstand current I <sub>cw</sub> (A) (≥ 12 I <sub>e</sub> max) .....	240 / 1s	P
	test voltage (V) .....	L1: 403 L2: 405 L3: 402	—
	r.m.s. test current (A) .....	L1: 244 L2: 246 L3: 243	—
	peak test current (A) .....	L1: 349 L2: 348 L3: 346	—
	power factor/time constant .....	L1: 0,93 L2: 0,94 L3: 0,94	—
	test duration (ms) .....	1015	—
8.3.5.1.5	Behaviour of the equipment during short-time withstand current test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.5.1.6	Condition of the equipment after short-time withstand current test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	- equipment is able to carry its rated current after normal closing operation		P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5.2	Short-circuit making capacity		N/A
	Rated short-circuit making capacity $I_{cm}$ (A) .....	-	N/A
	test voltage ( $1,05 \times U_e$ ) .....(V):	L1: - L2: - L3: -	—
	r.m.s. test current (A) .....	L1: - L2: - L3: -	—
	maximum peak test current (A) / factor n .....	-	N/A
	power factor/time constant .....	L1: - L2: - L3: -	N/A
	current duration (ms) .....	-	—
	Time interval between the cycles		—
8.3.5.2.5	Behaviour of the equipment during short-circuit making capacity test		N/A
	Test performed without:		—
	- endanger to the operator		N/A
	-cause damage to adjacent equipment		N/A
	No permanent arcing		N/A
	No flash over between poles and poles and frame		N/A
	No melting of the fuse in the detection circuit		N/A
8.3.5.2.6	Condition of the equipment after short-circuit making capacity test		N/A
	Immediately after the test equipment must work satisfactorily		N/A
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		N/A
	- equipment is able to carry its rated current after normal closing operation		N/A
8.3.5.3	Dielectric verification		P
	test voltage $2 \times U_e$ with a minimum of 1000V~ (V) .....	1000	—
	No flashover or breakdown		P
8.3.5.4	Leakage current		P
	test voltage ( $1,1 \times U_e$ ) (V) .....	440	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....	-	N/A
	Leakage current (mA) (other utilization categories) $\leq 2,0$ mA/pole .....	< 1	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.5.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	- conductor cross-section (mm <sup>2</sup> ) .....	2,5	—
	- test current I <sub>e</sub> (A) .....	20	—
	Measured temperature-rise .....	See appended table 8.3.5.5	P



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6	TEST SEQUENCE IV: CONDITIONAL SHORT-CIRCUIT CURRENT		
	Conditional short-circuit current test:		P
	<b>EFD 8, 1p: 100kA at 400V with 20A gG fuse-links</b>		
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated voltage (V) .....	20	—
	- rated current (A) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 x Ue) (V) .....	L1: 425 L2: - L3: -	—
	test current (kA) .....	L1: 100500 L2: - L3: -	—
	rated frequency (Hz) .....	50	—
	power factor .....	0,16	—
	Time constant (ms) .....	-	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (A) .....	L1: 3140 L2: - L3: - N: -	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 1790 L2: - L3: - N: -	—
	Fuse protected short-circuit making (equipment closing on to short-circuit)		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	0,95	—
	- point at which the measurement is made .....	Actuator	—
	- test speed during the fuse protected short-circuit making (m/s) .....	0,96	—
	- max. let-through current (A) .....	L1: 3520 L2: - L3: - N: -	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 1830 L2: - L3: - N: -	—

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during conditional short-circuit current test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after conditional short-circuit current test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage $2 \cdot U_e$ with a minimum of 1000V~ (V) .....: 1000		—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....: 440		—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....: -		N/A
	Leakage current (mA) (other utilization categories) $\leq 2,0$ mA/pole .....: < 1		P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....: ETI		—
	- manufacturer's model or type reference .....: CH 8 (8x31) / gG		—
	- rated current (A) .....: 20		—
	- power loss (W) .....: 2,3 max.		—
	- rated breaking capacity (kA) .....: 100		—
	- conductor cross-section (mm <sup>2</sup> ) .....: 2,5		—
	- test current $I_e$ (A) .....: 20		—
	Measured temperature-rise .....: See appended table 8.3.6.5		P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditional short-circuit current test:		P
	<b>EFD 8, 3p+N: 100kA at 400V with 20A gG fuse-links</b>		
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated voltage (V) .....	20	—
	- rated current (A) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 x Ue) (V) .....	L1: 428 L2: 429 L3: 427	—
	test current (kA) .....	L1: 100620 L2: 101250 L3: 100410	—
	rated frequency (Hz) .....	50	—
	power factor .....	0,15	—
	Time constant (ms) .....	-	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (A) .....	L1: 2260 L2: 4570 L3: 2450 N: 1850	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 1240 L2: 2030 L3: 1420 N: 950	—
	Fuse protected short-circuit making (equipment closing on to short-circuit)		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	0,95	—
	- point at which the measurement is made .....	Actuator	—
	- test speed during the fuse protected short-circuit making (m/s) .....	0,96	—
	- max. let-through current (A) .....	L1: 1540 L2: 3860 L3: 3710 N: 2140	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 970 L2: 1980 L3: 1310 N: 1020	—

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during conditional short-circuit current test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after conditional short-circuit current test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage $2 \cdot U_e$ with a minimum of 1000V~ (V) .....: 1000		—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....: 440		—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....: -		N/A
	Leakage current (mA) (other utilization categories) $\leq 2,0$ mA/pole .....: < 1		P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....: ETI		—
	- manufacturer's model or type reference .....: CH 8 (8x31) / gG		—
	- rated current (A) .....: 20		—
	- power loss (W) .....: 2,3 max.		—
	- rated breaking capacity (kA) .....: 100		—
	- conductor cross-section (mm <sup>2</sup> ) .....: 2,5		—
	- test current $I_e$ (A) .....: 20		—
	Measured temperature-rise .....: See appended table 8.3.6.5		P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditional short-circuit current test:		P
	<b>EFD 8, 1p: 50kA at 400V with 10A aM fuse-links</b>		
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / aM	—
	- rated voltage (V) .....	400	—
	- rated current (A) .....	10	—
	- rated breaking capacity (kA) .....	50	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 x Ue) (V) .....	L1: 425 L2: - L3: -	—
	test current (kA) .....	L1: 50930 L2: - L3: -	—
	rated frequency (Hz) .....	50	—
	power factor .....	0,14	—
	Time constant (ms) .....	-	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (A) .....	L1: 3140 L2: - L3: - N: -	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 1620 L2: - L3: - N: -	—
	Fuse protected short-circuit making (equipment closing on to short-circuit)		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	0,95	—
	- point at which the measurement is made .....	Actuator	—
	- test speed during the fuse protected short-circuit making (m/s) .....	0,96	—
	- max. let-through current (A) .....	L1: 2680 L2: - L3: - N: -	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 1950 L2: - L3: - N: -	—

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during conditional short-circuit current test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after conditional short-circuit current test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage $2 \cdot U_e$ with a minimum of 1000V~ (V) .....: 1000		—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....: 440		—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....: -		N/A
	Leakage current (mA) (other utilization categories) $\leq 2,0$ mA/pole .....: < 1		P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....: ETI		—
	- manufacturer's model or type reference .....: CH 8 (8x31) / gG		—
	- rated current (A) .....: 20		—
	- power loss (W) .....: 2,3 max.		—
	- rated breaking capacity (kA) .....: 100		—
	- conductor cross-section (mm <sup>2</sup> ) .....: 2,5		—
	- test current $I_e$ (A) .....: 20		—
	Measured temperature-rise .....: See appended table 8.3.6.5		P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditional short-circuit current test:		P
	<b>EFD 8, 3p+N: 50kA at 400V with 10A aM fuse-links</b>		
	Protective device details:		P
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / aM	—
	- rated voltage (V) .....	400	—
	- rated current (A) .....	10	—
	- rated breaking capacity (kA) .....	50	—
8.3.6.2	Fuse protected short-circuit withstand		P
	test voltage (1,05 x Ue) (V) .....	L1: 424 L2: 425 L3: 424	—
	test current (kA) .....	L1: 50660 L2: 51020 L3: 50280	—
	rated frequency (Hz) .....	50	—
	power factor .....	0,16	—
	Time constant (ms) .....	-	—
	Fuse protected short-circuit withstand (equipment in closed position)		
	- max. let-through current (A) .....	L1: 2470 L2: 3600 L3: 2260 N: 2030	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 1390 L2: 1670 L3: 1260 N: 2330	—
	Fuse protected short-circuit making (equipment closing on to short-circuit)		P
	- mean velocity of 15 manually under no-load conditions operations (m/s) .....	0,95	—
	- point at which the measurement is made .....	Actuator	—
	- test speed during the fuse protected short-circuit making (m/s) .....	0,96	—
	- max. let-through current (A) .....	L1: 2340 L2: 3210 L3: 2960 N: 3210	—
	- Joule integral I <sup>2</sup> dt (A <sup>2</sup> s) .....	L1: 980 L2: 1270 L3: 1430 N: 1050	—

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.6.2.5	Behaviour of the equipment during conditional short-circuit current test		P
	Test performed without:		—
	- endanger to the operator		P
	- cause damage to adjacent equipment		P
	No permanent arcing		P
	No flash over between poles and poles and frame		P
	No melting of the fuse in the detection circuit		P
8.3.6.2.6	Condition of the equipment after conditional short-circuit current test		P
	Immediately after the test equipment must work satisfactorily		P
	- required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	- equipment is able to carry its rated current after normal closing operation		P
8.3.6.3	Dielectric verification		P
	test voltage $2 \cdot U_e$ with a minimum of 1000V~ (V) .....: 1000		—
	No flashover or breakdown		P
8.3.6.4	Leakage current		P
	test voltage (1,1 $U_e$ ) (V) .....: 440		—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....: -		N/A
	Leakage current (mA) (other utilization categories) $\leq 2,0$ mA/pole .....: < 1		P
8.3.6.5	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....: ETI		—
	- manufacturer's model or type reference .....: CH 8 (8x31) / gG		—
	- rated current (A) .....: 20		—
	- power loss (W) .....: 2,3 max.		—
	- rated breaking capacity (kA) .....: 100		—
	- conductor cross-section (mm <sup>2</sup> ) .....: 2,5		—
	- test current $I_e$ (A) .....: 20		—
	Measured temperature-rise .....: See appended table 8.3.6.5		P



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7	TEST SEQUENCE V: OVERLOAD PERFORMANCE CAPABILITY		
8.3.7.1	Overload test		P
	<b>EFD 8, 1p</b>		
	ambient temperature 10-40 °C .....	23	—
	test enclosure W x H x D (mm x mm x mm) .....	-	—
	material of enclosure .....	-	—
	test current 1,6xI <sub>th</sub> e or 1,6xI <sub>th</sub> (A) .....	32	—
	cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) .....	2,5 / 1000	—
	Fuse-link details:		P
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	- time duration of the overload test (s) .....	818	—
	Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed		P
	Required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	The equipment has not undergone any impairment hindering such operation		P
8.3.7.2	Dielectric verification		P
	test voltage 2*U <sub>e</sub> with a minimum of 1000V~ (V) .....	1000	—
	No flashover or breakdown		P
8.3.7.3	Leakage current		P
	test voltage (1,1 U <sub>e</sub> ) (V) .....	440	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole .....	-	N/A
	Leakage current (mA) (other utilization categories) ≤ 2 mA/pole .....	< 1	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	Fuse links aged during the overload test are replaced by new fuse-links .....	Yes	P
	- conductor cross-section (mm <sup>2</sup> ) .....	2,5	—
	- test current I <sub>e</sub> (A) .....	20	—
	Measured temperature-rise .....	See appended table 8.3.7.4	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7.1	Overload test		P
	<b>EFD 8, 3p+N</b>		
	ambient temperature 10-40 °C .....	23	—
	test enclosure W x H x D (mm x mm x mm) .....	-	—
	material of enclosure .....	-	—
	test current 1,6xI <sub>the</sub> or 1,6xI <sub>th</sub> (A) .....	32	—
	cable/busbar cross-section (mm <sup>2</sup> ) / length (mm) .....	2,5 / 1000	—
	Fuse-link details:		P
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	- time duration of the overload test (s) .....	976	—
	Within 3 to 5 min after the fuse(s) has(have) operated (or 1 h), the equipment has been operated once, i.e. opened and closed		P
	Required opening force not greater than the test force of 8.2.5.2 and table 17 of IEC 60947-1		P
	The equipment has not undergone any impairment hindering such operation		P
8.3.7.2	Dielectric verification		P
	test voltage 2*U <sub>e</sub> with a minimum of 1000V~ (V) .....	1000	—
	No flashover or breakdown		P
8.3.7.3	Leakage current		P
	test voltage (1,1 U <sub>e</sub> ) (V) .....	440	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) ≤ 0,5 mA/pole .....	-	N/A
	Leakage current (mA) (other utilization categories) ≤ 2 mA/pole .....	< 1	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.7.4	Temperature-rise verification		P
	Fuse-link details (fuse-combination units only):		—
	- manufacturer's name, trademark or identification mark .....	ETI	—
	- manufacturer's model or type reference .....	CH 8 (8x31) / gG	—
	- rated current (A) .....	20	—
	- power loss (W) .....	2,3 max.	—
	- rated breaking capacity (kA) .....	100	—
	Fuse links aged during the overload test are replaced by new fuse-links .....	Yes	P
	- conductor cross-section (mm <sup>2</sup> ) .....	2,5	—
	- test current I <sub>e</sub> (A) .....	20	—
	Measured temperature-rise .....	See appended table 8.3.7.4	P

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.4	ELECTROMAGNETIC COMPATIBILITY TESTS		
8.4.1	Immunity		P
8.4.1.1	Equipment not incorporating electronic circuits: no tests necessary		P
8.4.1.2	Equipment incorporating electronic circuits:		N/A
	Equipment utilizing circuits in which all components are passive are not required to be tested		N/A
	All other equipment, requirements according to 7.3.3.2 of IEC 60947-1 and limits according table 6 apply		N/A
	Performed tests .....	-	N/A
	No unintentional separation or closing of contacts has occurred during these tests .....	-	N/A
8.4.2	Emission		P
8.4.2.1	Equipment not incorporating electronic circuits: no tests necessary		P
8.4.2.2	Equipment incorporating electronic circuits:		N/A
	Equipment utilizing circuits in which all components are passive are not required to be tested		N/A
	All other equipment, requirements according to 7.3.3.2 and limits according table 7 apply		N/A
	Performed tests .....	-	N/A

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
<b>Annex A (normative)</b>			
A	Equipment for direct switching of a single motor		
A.2	Additional rated duties.....:	-	N/A
A.2.1	- intermittent periodic duty		N/A
	- intermittent duty		N/A
	Classes of intermittent duty:		
	-class 1: up to 1 operating cycle per hour		N/A
	-class 3: up to 3 operating cycle per hour		N/A
	-class 12: up to 12 operating cycles per hour		N/A
	-class 30: up to 30 operating cycles per hour		N/A
	-class 120: up to 120 operating cycles per hour		N/A
A.2.2	Temporary duty .....	-	N/A
A.6	Mechanical durability:		
	Equipment mounted according to manufacturer's instruction		N/A
	Preferred number of no-load operating cycles expressed in millions.....:	-	N/A
	0,001 – 0,003 – 0,01 – 0,03 – 0,1 – 0,3 - 1		N/A
	If no mechanical endurance is stated by the manufacturer, a minimum mechanical endurance according to the class of intermittent duty shall be tested.		N/A
	Number of no-load operating cycles performed.....:	-	N/A
A.7	Electrical durability:		N/A
	- test according to manufacturer's instruction		N/A
A.8	Verification of making and breaking capacity:		
	- utilization category .....	-	—
	- rated operational voltage $U_e$ (V) .....	-	—
	- rated operational current $I_e$ (A) or power (kW) .....	-	—
	Conditions for make/break operations or make operations:		—
	- test voltage, $U = 1,05 U_e$ .....(V):	L1: - L2: - L3: -	—
	- test current, $I =$ .....x $I_e$ (A):	L1: - L2: - L3: -	—
	- power factor .....	L1: - L2: - L3: -	—

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	Conditions for make/break operations:		N/A
	- test voltage, $U = 1,05 U_e$ .....(V):	L1: - L2: - L3: -	—
	- test current, $I =$ .....x $I_e$ (A):	L1: - L2: - L3: -	—
	- power factor/ time constant .....	L1: - L2: - L3: -	—
	Number of make/break or make and break operations .....	-	N/A
	- recovery voltage duration ( $\geq 50$ ms)		N/A
	- current duration (ms) .....	-	—
	- time interval between operations .....	-	N/A
	Characteristic of transient recovery voltage if necessary:		N/A
	- oscillatory frequency (kHz) .....	-	—
	- measured oscillatory frequency (kHz) .....	L1: - L2: - L3: -	N/A
	- factor $\gamma$ .....	L1: - L2: - L3: -	N/A
8.3.3.3.5	Behaviour of the equipment during making and breaking capacity tests		N/A
	Test performed without:		—
	- endanger to the operator		N/A
	- cause damage to adjacent equipment		N/A
	No permanent arcing		N/A
	No flash over between poles and poles and frame		N/A
	No melting of the fuse in the detection circuit		N/A
8.3.3.3.6	Condition of the equipment after making and breaking capacity tests		N/A
	Immediately after the test equipment must work satisfactorily		N/A
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N/A
	- equipment is able to carry its rated current after normal closing operation		N/A

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
8.3.3.4	Dielectric verification		N/A
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	-	—
	No flashover or breakdown		N/A
8.3.3.5	Leakage current		N/A
	test voltage (1,1 $U_e$ ) (V) .....	-	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B): $\leq 0,5$ mA/pole .....	-	N/A
	Leakage current (other utilization categories): $\leq 2$ mA/pole) .....	-	N/A
8.3.3.6	Temperature-rise verification		N/A
	- conductor cross-section (mm <sup>2</sup> ) .....	-	—
	- test current $I_e$ (A) .....	-	—
	Measured temperature-rise .....	-	N/A
A.9	Operational performance test:		N/A
	- utilization category .....	-	—
	- rated operational voltage (V) .....	-	—
	- rated operational current (A) .....	-	—
	Test conditions for electrical operation cycles:		N/A
	- test voltage (V) .....	L1: - L2: - L3: -	—
	- test current (A) .....	L1: - L2: - L3: -	—
	- power factor/time constant .....	L1: - L2: - L3: -	—
	Number of cycles with current .....	-	N/A
	Number of cycles without current .....	-	N/A
	First test sequence (with/without current) .....	-	—
	Second test sequence (with/without current) .....	-	—
	- time interval between first and second test sequence .....	-	—
8.3.4.1.5	Behaviour of the equipment during the operational performance test		N/A
	Test performed without:		—
	- endanger to the operator		N/A
	-cause damage to adjacent equipment		N/A



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
	No permanent arcing		N/A
	No flash over between poles and poles and frame		N/A
	No melting of the fuse in the detection circuit		N/A
8.3.4.1.6	Condition of the equipment after making and breaking capacity tests		N/A
	Immediately after the test equipment must work satisfactorily		N/A
	- required opening force not greater than the test force of 8.2.5.2 and table 8		N/A
	- equipment is able to carry its rated current after normal closing operation		N/A
8.3.4.2	Dielectric verification		N/A
	test voltage: $2 \cdot U_e$ with a minimum of 1000V~ .....	-	—
	No breakdown or flashover		N/A
8.3.4.3	Leakage current		N/A
	test voltage (1,1 $U_e$ ) (V) .....	-	—
	Leakage current (utilization categories AC-20A, AC-20B, DC-20A and DC-20B) $\leq 0,5$ mA/pole .....	-	N/A
	Leakage current (other utilization categories) $\leq 2$ mA/pole .....	-	N/A
8.3.4.4	Temperature-rise verification		N/A
	- conductor cross-section (mm <sup>2</sup> ) .....	-	—
	- test current $I_e$ (A) .....	-	—
	Measured temperature-rise .....	-	N/A
A.10	Special tests		N/A

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict
<b>Annex C (normative)</b>			
C	Single pole operated three pole switches		
C.2	Additional-tests to be performed on single pole operated three pole switches		N/A
C.3.1	Test "8.3.3.3 Making and breaking capacities" according to test sequence I with following modifications:		N/A
	L1 and L2 are closed, L3 is subjected to the required make-break operation cycle .....	-	N/A
	L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle .....	-	N/A
	Test performed in a three phase circuit according to Figure 5 of IEC 60947-1		N/A
C.3.1	Test "8.3.4.1 Operational performance" according to test sequence II with following modifications:		N/A
	L1 and L2 are closed, L3 is subjected to the required make-break operation cycle .....	-	N/A
	L2 closed and L3 opened, L1 is subjected to the required make-break operation cycle .....	-	N/A
	Test performed in a three phase circuit according to Figure 5 of IEC 60947-1		N/A
C.3.2	Test "8.3.6.2 Fuse protected short circuit test" according to test sequence IV with following modifications:		N/A
	For the making test L1 is open and L2 closed, L3 is subjected to the required make operation cycle .....	-	N/A
	Test performed in a three phase circuit according to Figure 11 of IEC 60947-1		N/A
C.4	Condition of equipment after tests		N/A
	The equipment complies with the relevant clauses of 8.3.3.3.6, 8.3.4.1.6 and 8.3.5.2.6		N/A
C.5	Instruction for use		N/A
	The product literature includes following statement:		N/A
	These devices are intended for power distribution systems where switching and/or isolating of an individual phase may be necessary and shall not be used for the switching of the primary circuit of three-phase equipment.		N/A

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

7.1.4	TABLE: Clearance and creepage distance measurements of EFD 8, 1p			
Clearance cl and creepage distance dcr between:	cl (mm) required	cl (mm) measured	dcr (mm) required	dcr (mm) measured
Terminals and mounting plate	8	> 9	5,6	> 9
Each pole and the other poles connected together	-	-	-	-
Line terminal(s) connected together and load terminal(s) connected together	8	> 9	5,6	> 9
Main circuit and other circuits	-	-	-	-
Supplementary information: ---				

7.1.4	TABLE: Clearance and creepage distance measurements of EFD 8, 2p			
Clearance cl and creepage distance dcr between:	cl (mm) required	cl (mm) measured	dcr (mm) required	dcr (mm) measured
Terminals and mounting plate	8	> 9	5,6	> 9
Each pole and the other poles connected together	8	> 9	5,6	> 9
Line terminal(s) connected together and load terminal(s) connected together	8	> 9	5,6	> 9
Main circuit and other circuits	-	-	-	-
Supplementary information: ---				

7.1.4	TABLE: Clearance and creepage distance measurements of EFD 8, 3p+N			
Clearance cl and creepage distance dcr between:	cl (mm) required	cl (mm) measured	dcr (mm) required	dcr (mm) measured
Terminals and mounting plate	8	> 9	5,6	> 9
Each pole and the other poles connected together	8	> 9	5,6	> 9
Line terminal(s) connected together and load terminal(s) connected together	8	> 9	5,6	> 9
Main circuit and other circuits	-	-	-	-
Supplementary information: ---				

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.3.1	TABLE: Temperature-rise measurements of EFD 8, 1p		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	33	70	
Manual operating means: non-metallic	6	25	
Parts intended to be touched but not hand-held: non-metallic	12	40	
Parts which need not be touched during normal operation: non-metallic	27	50	
Supplementary information: ---			

8.3.3.1	TABLE: Temperature-rise measurements of EFD 8, 2p		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	42	70	
Manual operating means: non-metallic	9	25	
Parts intended to be touched but not hand-held: non-metallic	19	40	
Parts which need not be touched during normal operation: non-metallic	32	50	
Supplementary information: ---			

8.3.3.1	TABLE: Temperature-rise measurements of EFD 8, 3p+N		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	49	70	
Manual operating means: non-metallic	10	25	
Parts intended to be touched but not hand-held: non-metallic	21	40	
Parts which need not be touched during normal operation: non-metallic	34	50	
Supplementary information: ---			

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.3.6	TABLE: Temperature-rise measurements of EFD 8, 1p		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	37	80	
Manual operating means: non-metallic	8	35	
Parts intended to be touched but not hand-held: non-metallic	15	50	
Parts which need not be touched during normal operation: non-metallic	31	60	
Supplementary information: ---			

8.3.3.6	TABLE: Temperature-rise measurements of EFD 8, 2p		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	48	80	
Manual operating means: non-metallic	9	35	
Parts intended to be touched but not hand-held: non-metallic	22	50	
Parts which need not be touched during normal operation: non-metallic	34	60	
Supplementary information: ---			

8.3.3.6	TABLE: Temperature-rise measurements of EFD 8, 3p+N		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	52	80	
Manual operating means: non-metallic	10	35	
Parts intended to be touched but not hand-held: non-metallic	23	50	
Parts which need not be touched during normal operation: non-metallic	36	60	
Supplementary information: ---			

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.4.4	TABLE: Temperature-rise measurements of EFD 8, 1p		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	35	80	
Manual operating means: non-metallic	8	35	
Parts intended to be touched but not hand-held: non-metallic	16	50	
Parts which need not be touched during normal operation: non-metallic	30	60	
Supplementary information: ---			

8.3.4.4	TABLE: Temperature-rise measurements of EFD 8, 2p		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	47	80	
Manual operating means: non-metallic	9	35	
Parts intended to be touched but not hand-held: non-metallic	21	50	
Parts which need not be touched during normal operation: non-metallic	35	60	
Supplementary information: ---			

8.3.4.4	TABLE: Temperature-rise measurements of EFD 8, 3p+N		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	52	80	
Manual operating means: non-metallic	11	35	
Parts intended to be touched but not hand-held: non-metallic	25	50	
Parts which need not be touched during normal operation: non-metallic	38	60	
Supplementary information: ---			

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.5.5	TABLE: Temperature-rise measurements of EFD 8, 1p		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	35	80	
Manual operating means: non-metallic	7	35	
Parts intended to be touched but not hand-held: non-metallic	12	50	
Parts which need not be touched during normal operation: non-metallic	28	60	
Supplementary information: ---			

8.3.5.5	TABLE: Temperature-rise measurements of EFD 8, 3p+N		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	50	80	
Manual operating means: non-metallic	10	35	
Parts intended to be touched but not hand-held: non-metallic	23	50	
Parts which need not be touched during normal operation: non-metallic	37	60	
Supplementary information: ---			

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.6.5	TABLE: Temperature-rise measurements of EFD 8, 1p		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	37	80	
Manual operating means: non-metallic	9	35	
Parts intended to be touched but not hand-held: non-metallic	18	50	
Parts which need not be touched during normal operation: non-metallic	32	60	
Supplementary information: <b>After test with 100kA at 400V with 20A gG fuse-links</b>			

8.3.6.5	TABLE: Temperature-rise measurements of EFD 8, 3p+N		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	54	80	
Manual operating means: non-metallic	12	35	
Parts intended to be touched but not hand-held: non-metallic	26	50	
Parts which need not be touched during normal operation: non-metallic	39	60	
Supplementary information: <b>After test with 100kA at 400V with 20A gG fuse-links</b>			



IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict

8.3.6.5	TABLE: Temperature-rise measurements of EFD 8, 1p		
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals, max.: silver-plated copper		35	80
Manual operating means: non-metallic		9	35
Parts intended to be touched but not hand-held: non-metallic		15	50
Parts which need not be touched during normal operation: non-metallic		30	60
Supplementary information: <b>After test with 50kA at 400V with 10A aM fuse-links</b>			

8.3.6.5	TABLE: Temperature-rise measurements of EFD 8, 3p+N		
Temperature rise dT of part:		dT (K) measured	dT (K) required
Terminals, max.: silver-plated copper		58	80
Manual operating means: non-metallic		12	35
Parts intended to be touched but not hand-held: non-metallic		25	50
Parts which need not be touched during normal operation: non-metallic		42	60
Supplementary information: <b>After test with 50kA at 400V with 10A aM fuse-links</b>			

IEC 60947-3			
Clause	Requirement + Test	Result - Remark	Verdict




8.3.7.4	TABLE: Temperature-rise measurements of EFD 8, 1p		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	34	80	
Manual operating means: non-metallic	6	35	
Parts intended to be touched but not hand-held: non-metallic	13	50	
Parts which need not be touched during normal operation: non-metallic	31	60	
Supplementary information: ---			

8.3.7.4	TABLE: Temperature-rise measurements of EFD 8, 3p+N		
Temperature rise dT of part:	dT (K) measured	dT (K) required	
Terminals, max.: silver-plated copper	47	80	
Manual operating means: non-metallic	10	35	
Parts intended to be touched but not hand-held: non-metallic	23	50	
Parts which need not be touched during normal operation: non-metallic	35	60	
Supplementary information: ---			

**List of test equipment used:**

Measured quantity	Device	Manufacturer	Code
Voltage (tests up to 10kA)	Voltage divider 1:2000 Difference amplifier AM 502 Signal memory recorder TRA 800	AIT Tektronix W&W	- AM 502/1...3 TRA800
Current (tests up to 10kA)	Lin. Current transformer LGSSO Burden 1Ω Signal memory recorder TRA 800	Ritz AIT W&W	WLIN5000/1...3 - TRA800
Voltage (tests above 10kA)	Insulating measuring amplifier Arcus Signal memory recorder 2580-P	Rohrer Nicolet	T908D 2580-P
Current (tests above 10kA)	Lin current transformer LGSSO Burden 0,7mΩ Signal memory recorder 2580-P	Ritz AIT Nicolet	WLIN6000.HVF/1...3 - 2580-P
Current (tests at reduced voltage)	Current transformer GE 4461 Current transformer AETt10 True-RMS amperemeter Cl. 0,5 Digital multimeter Fluke 185	Goerz Siemens Norma Fluke	WI600/1...3 WI4000/1...3 A0,5/4 FLUKE185/2
Transient recovery voltage	Adjustment equipment for TRV Oscilloscope G 801.1	AIT Tektronix	- G801.1
Dielectric properties	High-voltage test equipment 90-1F with measuring equipment Impulse tester 35 Impulse voltmeter 64M Oscilloscope 9430	Elabo Haefely Haefely Le Croy	HSG5KV G304 G502 G805
Leakage current	High-voltage test equipment 90-1F Digital multimeter Fluke 185 Digital multimeter Fluke 187	Elabo Fluke Fluke	HSG5KV FLUKE185/2 G922
Time	Signal memory recorders Digital stopwatch	W&W, Nicolet Quantum	TRA800, 2580-P 938-3
Temperature	Data Logger Unit 34970A Temperature meter TESTO 901	Agilent Testoterm	942 TESTO
Abnormal heat and fire	Glow-wire test device with measuring equipment	Friborg	GLOW
Mechanical strength of terminals	Test equipment	AIT	MSD
Insertability of unprepared conductors	Test gauge	AIT	Gauge 1...16
Strength of actuator mechanism	Test equipment	Sauter GmbH	FH1K
Degree of protection	Test probe, dust chamber Test equipment for ingress of water	PTL, Friborg PTL, Friborg	PTL1...3, DUST X1...X4
Clearances, creepage distances	Digital slide gauge	Spiral	SCHUB-1

**TEST REPORT SUMMARY**

<b>Report Reference No. ....: 2.03.02769.1.0/EFD8/CCA</b>	
Date of issue.....: 17.04.2014	
Tested by (name + signature) .....: Ing.J.Ainetter	 
Witnessed by (name + signature) .....: ---	
Approved by (name + signature).....: Ing.K.Farhofer	
Supervised by (name + signature) ....: ---	
<b>Testing Laboratory .....: AIT Austrian Institute of Technology GmbH</b>	
Address .....: 1210 Vienna, Giefinggasse 2, AUSTRIA	
Testing procedure .....: <input checked="" type="checkbox"/> ENEC/CCA-TL <input type="checkbox"/> TMP <input type="checkbox"/> WMT <input type="checkbox"/> SMT	
<b>Testing location .....: AIT Austrian Institute of Technology GmbH</b>	
Address .....: 1210 Vienna, Giefinggasse 2, AUSTRIA	
<b>Applicant .....: ETI Elektroelement d.d.</b>	
Address .....: Obrezija 5, 1411 Izlake, SLOVENIA	
<b>Manufacturer .....: ETI Elektroelement d.d.</b>	
Address .....: Obrezija 5, 1411 Izlake, SLOVENIA	
<b>Product .....: Fuse-switch-disconnectors for cylindrical fuse-links 8x31</b>	
Model/Type reference .....: EFD 8	
Trademark .....: ETI	
Ratings .....: 400V / up to 20A (with gG) / 50/60Hz / 1p up to 3p+N 400V / up to 10A (with aM) / 50/60Hz / 1p up to 3p+N	
Certification Scheme .....: <input type="checkbox"/> ENEC <input checked="" type="checkbox"/> CCA <input type="checkbox"/> Other: _____	
<b>Standard(s).....: EN 60947-3:2009+A1:2012 in conjunction with EN 60947-1:2007+A1:2011</b>	
<input checked="" type="checkbox"/> The text of the a.m. European Standard was approved by CENELEC under the Unique Acceptance Procedure and is identical with the corresponding IEC Publication.	
<input type="checkbox"/> The text of the a.m. European Standard was approved by CENELEC with agreed common modifications and is <u>not</u> identical with the corresponding IEC Publication.	
This EN test report consists of the following parts:	
<input checked="" type="checkbox"/> <b>IEC TRF No. IEC60947_3C</b>	Report Reference No. .... : 2.03.02769.1.0/EFD8/CB
<input checked="" type="checkbox"/> <b>EN Common modifications SNCs and A-deviations</b>	Report Reference No. or Annex No. .... : 2.03.02769.1.0/EFD8/CCA
<b>Copyright © 2013 EEPCA, Paris, France. All rights reserved.</b>	
This ECS document together with the test report is only valid if signed by an approved ENEC or CCA Testing Laboratory and accompanied by the associated ENEC Licence or CCA Notification of Test Results, issued by a Certification Body member of ECS.	

<b>EN 60947-3</b>			
<b>Clause</b>	<b>Requirement + Test</b>	<b>Result - Remark</b>	<b>Verdict</b>
<b>Annex 1</b>	<b>COMMON MODIFICATIONS</b>		<b>P</b>
	No modifications to IEC 60947-1 and IEC 60947-3		P
	EN 60947-1 and EN 60947-3 summarizes IEC 60947-1 and IEC 60947-3		P
<b>Annex 2</b>	<b>SPECIAL NATIONAL CONDITIONS</b>		<b>N/A</b>
<b>Annex 3</b>	<b>A - DEVIATIONS</b>		<b>N/A</b>