



Accredited by BMWA, number GZ 92714/237-IV/9/00

Test Report

Project Designation

TYPE TEST AT AUXILIARY CONTACT UNITS TYPE PS EFI AND PS STV

Client ETI Elektroelement d.d.
1411 Izlake, Obrezija 5
SLOVENIJA

Manufacturer ETI Elektroelement d.d.
1411 Izlake, Obrezija 5
SLOVENIJA

Standard EN 62019:1999

Order from / No 05/2001 / ---

Project number 2.03.00090.1.0/PSEFI-PSSTV

Test Engineer Ing.J.Ainetter

Date of issue	22.10.2001
Total number of issues / No.	1 / 1
Number of pages	2
Annexes	CCA-Report: 2.03.00090.1.0/PSEFI/CCA CCA-Report: 2.03.00090.1.0/PSSTV/CCA

The results relate exclusively to the terms tested.
This report may only be reproduced or published in full, without omissions, alterations or additions.
The reproduction or publishing of extracts from this report require the written approval of the research center.

TECHNICAL DATA

(according to specification of the manufacturer)

	PS EFI	PS STV
Rated operational voltage U _e :	AC 230V DC 110V	AC 230V DC 110V
Rated operational current I _e :	AC 6A DC 1A	AC 6A DC 1A
Rated frequency:	AC 50/60Hz DC	AC 50/60Hz DC
Utilization category:	AC-12 DC-12	AC-12 DC-12
Rated insulation voltage U _i :	AC 230V	AC 230V
Rated conditional short-circuit current:	1000A (with 20A fuse-link)	1000A (with 20A fuse-link)
Number of poles:	2	2
Number and kind of contacts:	1NO+1NC or 2NO or 2NC	1NO+1NC or 2NO or 2NC
Contact classification:	Zb or X or Y	Zb or X or Y
Number of positions of contacts:	2	2
Method of operation:	Indirect by: EFI-2, EFI-4	Indirect by: STV D02